



DENOMINAZIONE		Generale Differenziale	Presas 1	Presas 2	Presas 3	Presas 4	Presas 5			
INTERRUTTORE	MAGNETOTERMICO:									
	POLI In (A)		4 32	4 16						
	Ith (A) Pdi (kA)		32 10	16 10						
	Im (A)		320	160						
PRESA	DIFFERENZIALE:									
	POLI In (A)	4 63								
	Idn (A)	0,03 cl.A								
	POLI PRESA:		3F+T - 32A	3F+T - 16A	F+N+T - 16A	F+N+T - 16A	F+N+T - 16A			
PRESA	INT. MAGNETOTERM.									
	POLI In (A)									
	Ith (A) Pdi (kA)									
	Im (A)									
	FUSIBILI:									
	TIPO In (A)									



via G. Galilei, 37/b 42027 Montecchio Emilia (RE)  
 tel. 0522.864644 fax 0522.866145  
 e-mail: info@friggeri.com web: www.friggeri.com

QUADRO TIPO: AB-V010103P  
 POTENZA QUADRO: 35kW  
 MATRICOLA:

Nome file: AB-V010103P  
 Foglio: 1 / Sg. Foglio: /