



DENOMINAZIONE		Int.Aut. Diff.	Presa 1		Presa 2		Presa 3		Presa 4					
INTERRUTTORE	MAGNETOTERMICO:		4	32	3	16	1N	32	1N	16				
	POLI In (A)		32	10	16	10	32	4,5	16	4,5				
	Ith (A) Pdi (kA)		320		160		320		160					
	Im (A)													
PRESA	DIFFERENZIALE:													
	POLI In (A)	4	63											
	Idn (A)	0,03 cl.A												
	POLI PRESA:		3F+N+T 32A	3F+T 16A	F+N+T - 32A	F+N+T 16A								
PRESA	INT. MAGNETOTERM.:													
	POLI In (A)													
	Ith (A) Pdi (kA)													
	Im (A)													
FUSIBILI:														
TIPO In (A)														



via G. Galilei, 37/b 42027 Montecchio Emilia (RE)  
 tel. 0522.864644 fax 0522.866145  
 e-mail: info@friggeri.com web: www.friggeri.com

QUADRO TIPO:

POTENZA QUADRO:

MATRICOLA:

PI-DS100111SP 18kW

Nome file

PI-DS100111SP

Foglio

1

Sg. Foglio

/