



DENOMINAZIONE		Int. Differenz. Generale	Presa 1	Presa 2	Presa 3	Presa 4	Presa 5	Presa 6	Presa 7	Presa 8						
INTERRUTTORE	MAGNETOTERMICO:															
	POLI	In (A)	1N	16	1N	16	1N	16	1N	16	1N	16	1N	16	1N	16
	I _{th} (A)	P _{di} (kA)	16	4,5	16	4,5	16	4,5	16	4,5	16	4,5	16	4,5	16	4,5
	I _m (A)		160	160	160	160	160	160	160	160	160	160	160	160	160	160
PRESA	DIFFERENZIALE:															
	POLI	In (A)	2	40												
	I _{dn} (A)		0,03 "A"													
	POLI PRESA:		F+N+T - 16A	F+N+T - 16A	F+N+T - 16A	F+N+T - 16A	F+N+T - 16A	F+N+T - 16A	F+N+T - 16A	F+N+T - 16A						
PRESA	INT. MAGNETOTERM.:															
	POLI	In (A)														
	I _{th} (A)	P _{di} (kA)														
	I _m (A)															
PRESA	FUSIBILI:															
	TIPO	In (A)														



via G. Galilei, 37/b 42027 Montecchio Emilia (RE)
 tel. 0522.864644 fax 0522.866145
 e-mail: info@friggeri.com web: www.friggeri.com

QUADRO TIPO:

POTENZA QUADRO:

MATRICOLA:

PS-DS000000080SP

Nome file

PS-DS000000080SP

Foglio

1

Sg. Foglio

/